Uptime Institute®

23 June 2020

Andres Felipe Giraldo Henao
Gerente Tecnico Gtd Colombia
Gtd Colombia
Carrera 45 No 14-111
Medellin, Antioquia, 050022
Colombia

Re: Tier III Certification of Constructed Facility for the Gtd Colombia – Datacenter El Poblado, Phases 1 and 2 in Medellin, Colombia

Dear Andres Felipe Giraldo Henao,

Uptime Institute Professional Services is pleased to announce the Tier Certification of Constructed Facility for the mutually dependent phases of Gtd Colombia – Datacenter El Poblado, Phases 1 and 2 as fulfilling Tier III Concurrently Maintainable criteria. This Certification is based on the design and on-site verification of the constructed facility completed 13 December 2019 and documentation subsequently submitted through 2 June 2020.

This Certification recognizes the combination of the mutually dependent phases of the Gtd Colombia – Datacenter El Poblado, Phase 1 and the Gtd Columbia – Datacenter El Poblado, Phase 2 and supersedes the Tier III Certification of Constructed Facility for Gtd Colombia – Datacenter El Poblado, Phase 1 dated 1 February 2016.

This Certification recognizes the Gtd Colombia – Datacenter El Poblado, Phases 1 and 2 as supporting any planned work on the site infrastructure without disrupting computer room power and cooling capacity. This Tier III Certification is based on a total IT load of 276 kilowatts (kW). This includes 136 kW in Sala Servidores Piso 2 room and 2 kW in its MDA room for a total of 138 kW and 136 kW in Sala Servidores Piso 3 room and 2 kW in its MDA room for a total of 138 kW.

Tier III Concurrently Maintainable criteria are founded on the capability to complete planned facility maintenance or modifications on a scheduled basis; equipment failures or distribution path faults may lead to unplanned outages. Certain operations-related errors (such as procedural errors during reconfiguration of redundant systems, components, or site infrastructure equipment) may still impact the critical load.

This Tier Certification is valid until the facility is modified, including any changes to the capacity components or distribution paths depicted in the design identified above, and submitted for review. This Certification is subject to the limitations set forth in Schedule I hereto and incorporated herein.

The Tier III Certification of Constructed Facility represents the culmination of Gtd Colombia's investment and commitment to site uptime availability.

Congratulations on this significant achievement.

Sincerely,

Christopher Brown
Chief Technical Officer